

Addendum No.1, IFB 13-47



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR

To: Prospective bidders IFB 13-47, Walkway Canopy at Ice Rink

From: Karen Mancini, Asst. Purchasing Director

Date: December 5, 2012

Re: Questions, Answers and Clarifications

Addendum No. 1 to IFB 13-47

The City is issuing this addendum to IFB 13-47, Walkway Canopy at Ice Rink.

1. The Bid Due Date is confirmed as follows:

Bid Due Date confirmed for: Monday, 12/10/2012 @ 11:00 AM

2. Questions, Answers and Clarifications

3. Mandatory Pre-Bid Conference Attendees List

****PLEASE BE SURE TO ACKNOWLEDGE THIS ADDENDUM ON
PRICE PROPOSAL PAGE****

Somerville City Hall • 93 Highland Avenue • Somerville, Massachusetts 02143
(617) 625-6600, Ext. 3400 • TTY: (617) 666-0001 • Fax: (617) 625-1344

1



www.ci.somerville.ma.us

Addendum No.1, IFB 13-47

2. Questions, Answers and Clarifications

Q. Please specify and clarify; is this project based on Prevailing Wages?

A. No this is a M.G.L. 30B project as there is no building installation required. It is for the manufacture and installation of the Canopy on the walkway only. The installation will require bolts in the existing concrete.

Q. What is the thickness of the slab in the walkway?

A. Record plans are not available for this portion of the site. Sidewalks are anticipated to be approximately 4" – 5" thick.

Q. Please provide information on the underground electrical on site.

A. As-Bid plans are available for this portion of the site and will be provided to the low-bidder. Regardless, it is required that Dig Safe be notified prior to the start of any work.

3. Mandatory Pre-Bid Conference Attendees List

Morgan Awning,	10 Atlantic Avenue, Weymouth
Wes Construction Corp.	650 Industrial Drive, Halifax
Rob King	City of Somerville, Engineering
Orazio DeLuca	City of Somerville, Purchasing

